

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. Contract Number		Page of Pages	
				1		1	
2. Amendment/Modification Number GF-2014-B-0219-003		3. Effective Date September 19, 2014		4. Requisition/Purchase Request No.		5. Solicitation Caption See Below Caption	
6. Issued By: University of the District of Columbia Capital Procurement Division 4200 Connecticut Avenue, NW, Room C03 Washington, DC 20008				7. Administered By (If other than line 6) University of the District of Columbia Capital Procurement Division 4200 Connecticut Avenue, NW, Room C03 Washington, DC 20008			
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)				9A. Amendment of Solicitation No. GF-2014-B-0219			
				9B. Dated (See Item 11) 8/29/2014			
				10A. Modification of Contract/Order No.			
				10B. Dated (See Item 13) X			
Code		Facility					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. Accounting and Appropriation Data (If Required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14							
A. This change order is issued pursuant to: (Specify Authority) The changes set forth in item 14 are made in the contract/order no. in item 10A.							
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.							
C. This supplemental agreement is entered into pursuant to authority of:							
X D. Other (Specify type of modification and authority) Title 8, DCMR, Section 3016.3							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copy to the issuing office.							
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) Invitation for Bids No. GF-2014-B-0219 for Energy Metering Upgrade at the University of the District of Columbia is hereby amended as follows: 1. To provide answers to questions submitted by a potential bidder (Attachment A).							
Except as provided herein, all terms and conditions of the document referenced in item (9A or 10A) remain unchanged and in full force and effect							
15A. Name and Title of Signer (Type or print)				16A. Name of Contracting Officer MARY ANN HARRIS			
15B. Name of Contractor		15C. Date Signed		16B. District of Columbia MARY ANN HARRIS		16C. Date Signed 9/19/14	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

AMENDMENT NO. 3 TO IFB NO. GF-2014-B-0219

ATTACHMENT A

QUESTIONS AND ANSWERS

Questions & Responses

<p>1 Buildings listed below are missing some information regarding pipe sizes. This is mostly important for steam meters. Please provide steam pipe sizes at a minimum. Bldgs: 38/39, 44, 46E, 46W, 47, 52</p>	<p>Pipe sizes as follows:</p> <table border="1"> <thead> <tr> <th>Building</th> <th>Size</th> </tr> </thead> <tbody> <tr> <td>Building 38/39</td> <td>4"</td> </tr> <tr> <td>Building 44</td> <td>4"</td> </tr> <tr> <td>Building 46E</td> <td>2-1/2"</td> </tr> <tr> <td>Building 46W</td> <td>2"</td> </tr> <tr> <td>Building 47</td> <td>6"</td> </tr> <tr> <td>Building 52</td> <td>No Steam</td> </tr> </tbody> </table>	Building	Size	Building 38/39	4"	Building 44	4"	Building 46E	2-1/2"	Building 46W	2"	Building 47	6"	Building 52	No Steam
Building	Size														
Building 38/39	4"														
Building 44	4"														
Building 46E	2-1/2"														
Building 46W	2"														
Building 47	6"														
Building 52	No Steam														
<p>2 What are each buildings load for steam and the operating working steam pressure?</p>	<p>Steam Operating Pressure: Main Header (at Plant): 60-65 PSIG Pressure Reducing Station (located in Buildings): 10-15 PSIG</p> <p>Design Steam Load as follows:</p> <table border="1"> <thead> <tr> <th>Building</th> <th>Lb/hr</th> </tr> </thead> <tbody> <tr> <td>Building 32</td> <td>2000</td> </tr> <tr> <td>Building 38 & 39</td> <td>8440</td> </tr> <tr> <td>Building 41</td> <td>4000</td> </tr> <tr> <td>Building 42</td> <td>6800</td> </tr> <tr> <td>Building 43</td> <td>845</td> </tr> <tr> <td>Building 44</td> <td>7160</td> </tr> </tbody> </table>	Building	Lb/hr	Building 32	2000	Building 38 & 39	8440	Building 41	4000	Building 42	6800	Building 43	845	Building 44	7160
Building	Lb/hr														
Building 32	2000														
Building 38 & 39	8440														
Building 41	4000														
Building 42	6800														
Building 43	845														
Building 44	7160														

**University of the District of Columbia
Energy Metering Upgrade at the University of the District of Columbia**

Solicitation No. GF-2014-B-0219

	<table border="1"> <tr> <td>Building 46 E</td> <td>2113</td> </tr> <tr> <td>Building 46 W</td> <td>600</td> </tr> <tr> <td>Building 47</td> <td>9563</td> </tr> <tr> <td>Building 38 & 39</td> <td>8440</td> </tr> </table>	Building 46 E	2113	Building 46 W	600	Building 47	9563	Building 38 & 39	8440
Building 46 E	2113								
Building 46 W	600								
Building 47	9563								
Building 38 & 39	8440								
<p>3 Please confirm that we will use the UDC credentials for setting up the data share to EPA.</p>	<p>UDC would be set up as a sub-group under the District government. Our buildings would be District assets under the program.</p>								
<p>4 Please provide a manufacturer and/or part number for the UDC campus standard switches.</p>	<p>Existing Standard: UDC IDF Standard – Stackable 3850New Installation Standard: IDF/MDF Alternate Configuration Cisco 4510 Chassis</p> <p>The switch should be a New Installation Standard: IDF/MDF Alternate Configuration Cisco 4510 Chassis.</p> <p>The Contractor is to build out an equipment rack in the plant manager’s office (building 43) to include a:</p> <ul style="list-style-type: none"> ▪ Switch ▪ Patch Panel ▪ Cable Management ▪ Johnson Controls Server (moved from adjacent room)mount in the rack in the corner. <p>For additional information refer to the UDC OIT Infrastructure Standard, Version 1.3. All switches are owned by the University, not DC-Net as indicated in the Standard.</p>								
<p>5 Please confirm UDC IT will be responsible for programming and port setup on the new 48 port switch.</p>	<p>UDC will configure the port switch for lines connected to a network switch. Request an IP address for devices and identify the switch and port location prior to making the request. Provide this information in the shop drawing submittal and provide advanced notice.</p>								

**University of the District of Columbia
Energy Metering Upgrade at the University of the District of Columbia**

Solicitation No. GF-2014-B-0219

<p>6 Please confirm the Domestic Water Meters w/Bypass are existing and shown for reference only.</p>	<p>The notation "domestic water meter with bypass" indicates the existing to remain meters and are shown for purposes of locating the new DDC flow meters. New meter locations are shown downstream of existing meters.</p>
---	---